



Confirmation

eurofins

Eurofins Product Testing A/S confirms that a sample of a primer (Substrate Specific Applications, Porous Material (except wood)) with the name

Uzin PE 260

supplied by

Uzin Utz AG

showed low VOC contents in a test in accordance with SCAQMD rule 1168, as specified in LEED credit IEQ 4.1 (adhesives and sealants).

VOC contents was below the limit value specified as 50 grams VOC minus water per liters for Substrate Specific Applications, Porous Material (except wood).

The test has been performed in October 2009, see test report no. 770902_1168.

Volatiles content (incl. water) was calculated by Eurofins.

Water content was determined by Eurofins.

Solids content was determined by Eurofins.

With this confirmation, use of product Uzin PE 260 may qualify for fulfillment of LEED credit IEQ 4.1 (adhesives and sealants).

16 October 2009

Thomas Neuhaus

Head of product emission test centre

Eurofins Product Testing A/S
Smedeskovvej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com